



Figura/Figure 1

Figura/Figure 2

Figura/Figure 3

Figura/Figure 4

- ESP** Los componentes de la gama AVANT presión tipo H deben instalarse con el extremo macho arriba. Véase figura 1.
- Para este tipo de presión, un abundante cordón de sellante debe ser aplicado en el canal ubicado en el extremo macho de cada componente. Véase figura 2. Debe utilizarse como sellante una silicona resistente hasta 350 °C.
- Tras llenar de sellante el canal de un componente, el siguiente componente se conecta como se indica en la figura 3.
- La unión entre dos elementos debe asegurarse con la abrazadera de unión. Véase figura 4.
- La chimenea no puede usarse hasta pasadas 24 horas después de la aplicación del sellante para permitir un correcto curado.

- ENG** AVANT pressure type H chimney components must be installed with end male on the top. See figure 1.
- For pressure type required, an abundant sealant cord must be applied in the groove located at the end male of each component. See figure 2. A silicone sealant resistant up to 350 °C must be used.
- Once the component with the groove is full of sealant, the next component is connected as shown in figure 3.
- The joint between both elements must be fixed with the locking band. See figure 4.
- The chimney can not be used for 24 hours after apply the sealant to allow a right hardening.